

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No.

Dated: 10/06/2025

It is certified that an inspection team headed by Dr. Navneet Kumar

(Name of Officers with designation) from MOIC Islamnagar PHED

inspected the S.R. Convent School Bilsa Road Islamnagar

(Name & Address of the school) on 10/6/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1290/M-11/27 dated 26/5/2025

of S.R. Convent School (PHED Lab) certified that the

S.R. Convent School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till .....

Navneet

Signature with Seal: विकित्सा अधिकारी

Name: सामुदायिक स्वास्थ्य केंद्र

Designation: इस्लामनगर (बदायुन)

Name & Address of the Office / Department: .....

To

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Prabhat

प्रबन्धक

एसओ आरओ कान्वेंट स्कूल  
इस्लामनगर (बदायुन)

S.R. Convent

Principal

S.R. Convent School  
Islamnagar (Badaun)



कार्यालय अधिशासी अभियन्ता,  
खण्ड कार्यालय, उत्तर प्रदेश जल निगम (ग्रामीण), बदायूँ।

मा0 कांशीराम आवसीय कालोनी के पीछे, ग्राम- खेड़ा बुजुर्ग, बदायूँ-243601

E-mail -eejalnigambudaun@gmail.com

पत्रांक -1298 / M-11 / 27

दिनांक 26-05-2025

सेवा में,

एस0आर0 कॉन्वेंट स्कूल,  
ग्राम- विक्रमपुर चरसौरा, बिल्सी रोड़,  
विकास खण्ड- इस्लामनगर,  
जनपद- बदायूँ।


विषय:- प्रेषित किये गये जल नमूने की जाँच के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय पत्रांक- शून्य, दिनांक- 23.05.2025 के द्वारा 01 नग जल नमूना जनपदीय जल परीक्षण प्रयोगशाला, उ0प्र0 जल निगम (ग्रामीण), बदायूँ पर Chemical & Bacteriological जाँच कराने हेतु उपलब्ध कराया गया है। जल नमूने की Chemical & Bacteriological जाँच कर ली गई है। जाँच रिपोर्ट निर्धारित प्रारूप पर संलग्न कर प्रेषित है।

संलग्नक- जाँच रिपोर्ट।


भवदीय


  
अधिशासी अभियन्ता

पृ0सं0 एवं दिनांक- उपरोक्तानुसार  
प्रतिलिपि-

सहायक अभियन्ता / जू0इं0 (प्रयोगशाला), बदायूँ को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।

अधिशासी अभियन्ता

  
प्रबन्धक  
एस0 आर0 कॉन्वेंट स्कूल  
इस्लामनगर (बदायूँ)

  
Principal  
S.R.Convent School  
Islamnagar (Badaun)



**Water Analysis Report**  
**District Level Water Analysis Laboratory**  
**U.P. Jal Nigam (Rural), Budaun**

TC-12365

Report No.	45	Date	23/05/2025	Page No	01
<b>Customer Details</b>					
Name & Address	Office of Executive Engineer, Khand Karyalay, U.P Jal Nigam (Rural), Behind Manya, Kashiram Awasiya Colony, Kheda bujurg, District-Budaun.				
Reference Letter No. & Date	620/011-Prayogshala/23 ,Date:- 23/05/2025				
<b>Basic Details of the Sample</b>					
District	Budaun	Block	Islamnagar		
Gram Panchayat	Vikrampur Charsaura	Village	Vikrampur Charsaura		
Habitation		Location	S.R Convent School, Vikrampur Charsaura, Bilsa Road, Islamnagar, Budaun.		
Water Source	Submersible Pump	Sample No.	45		
Quantity of the Sample	1Ltr	Date of Sample Collection	23/05/2025		
Receiving Date	23/05/2025	Sample Collector	Nazreen Begum		
Sample Depositor	Nazreen Begum				
Analysis Start Date	23/05/2025	Analysis Completion Date	26/05/2025		
<b>Environmental Condition</b>					
Temperature	25±3°C	Humidity	50±15 %		

S.No	Analysed Parameter	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Odour	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2018
2	Taste	Agreeable	Agreeable	Agreeable	IS:3025(Part-8):2023
3	pH @25°C	7.25	6.5-8.5	6.5-8.5	IS 3025(Part 11):2022
4	Turbidity(NTU)	0.72	1	5	IS 3025 (Part 10):2017
5	Total Dissolved Solid(mg/L)	249	500	2000	IS 3025 (Part 16):2019
6	Chloride(mg/L)	98	250	1000	IS 3025(Part 32):1988
7	Total Alkalinity(mg/L)	121	200	600	IS 3025 (Part 23):2023
8	Total Hardness(mg/L)	159	300	600	IS 3025 (Part 21):2009
9	Calcium(mg/L)	24.48	75	200	IS 3025 (Part 40):2023
10	Magnesium	41.38	30	100	IS 3025 (Part 46):2023

Note	1. This certificate refers only to the particular sample(s) submitted for testing
	2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Head of the Laboratory
	3. The Test results reported in this certificate are valid at the time of and under the stated conditions of Measurements
	4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of Tests report unless Otherwise Specified.
	5. Parameters above Permissible Limit This are Written in Bold.



*Radha*  
प्रबन्धक

एसओ आरओ कान्वेंट स्कूल  
इस्लामनगर (बदायूं)



*S. K. Gupta*  
Principal  
S.R. Convent School  
Islamnagar (Badaun)



# Water Analysis Report

DISTRICT LEVEL WATER ANALYSIS LABORATORY, U.P JAL NIGAM (BUDAUN)

## BACTERIOLOGICAL SAMPLE TEST REPORT

Report No. 45 Date 23/05/2025 Page No. 01

### Customer Details

Name & Address Office of Executive Engineer, Khand Karyalay, U.P Jal Nigam (Rural), Behind Manya, Kashiram Awasiya Colony, Kheda bujurg Budaun.  
620/011-Prayogshala/23 Dated 23/05/2025.  
Ref Letter No.&Date

### Basic details of sample


District	Budaun	Block	Islamnagar
Gram Panchayat	Vikrampur Charsaura	Village	Vikrampur Charsaura
Habitation	-	Location	S.R Convent School, Vikrampur Charsaura, Bilsa Road, Islamnagar, Budaun.
Water Source	Submersible Pump	Sample No.	45
Quantity of Sample	1L	Date of Sample Collection Date	23/05/2025
Receiving Date	23/05/2025	Sample Collector	Nazreen Begum
Analysis Start Date	23/05/2025	Analysis Completion Date	26/05/2025
<b>Environmental Condition</b>			
Temperature	25±3°C	Humidity	50±15%


### Technical Data of Analysis


Sr.No.	Units	Observed Value	Specified Values as per IS 10500:2021		Ref. Method of Analysis	
			Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	7
1	Total coliform	CFU	0.0	No Relaxation	0.0 CFU/100mL	APHA23 <sup>rd</sup> Edition:2017
2	E.Coli	CFU	0.0	No Relaxation	0.0 CFU/100mL	APHA23 <sup>rd</sup> Edition:2017

### Note:-

- 1.This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of laboratory.
3. The Test result reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.

  
प्रबन्धक  
एसओ आरओ कान्वेंट स्कूल  
इस्लामनगर (बदायूँ)

  
Principal  
S.R.Convent School  
Islamnagar (Badaun)

  
Result approved by  
Laboratory Microbiologist